

INDIAN INSTITUTE OF TECHNOLOGY KANPUR
INSTITUTE WORKS DEPARTMENT
ELECTRICAL & AIR-CONDITIONING DIVISION

No. 27/AC/EE/2021/197

Dated 09-11-2021

QUOTATION NOTICE

M/s

Sealed quotations are invited from the specialized agency/empanelled contractor by the undersigned on behalf of the Director, IIT Kanpur for "**Replacement of defective electric motor and starter at Lecture Hall 2 AHU room..**" As per enclosed Bill of Quantity/ overleaf, so as to reach in this office on or before 17-11-2021 upto 3.00 PM and the quotation will be opened on the same day at 3.30PM in the presence of quotationers or their representative who want to be present.


The terms and conditions of the quotation are as under:

11. The quotations should be submitted in a properly sealed envelop, addressed to the undersigned. The enquiry nos. and date should invariably quoted on the top of the envelop.
12. The time allowed for carrying out the above noted work is 21(Twenty One) Days.
13. The rates quoted should be exclusive of GST, no other tax is payable except GST. GST shall be applicable as per Govt. norms..
14. Security @ 7.5% shall be deducted from the bills which shall be released on successful completion of defect liability period of six months.
15. The estimated cost of quotation is **Rs.54667/-**. The required earnest money of **Rs. 1094/-** is to be submitted in the form of FDR pledged in favour of the Director, IIT Kanpur alongwith the quotation. The earnest money of the unsuccessful quotationers will be returned within one month's time.
16. The quotations shall remain valid for 90 days from the date of opening.
17. Income tax will be recovered as per notification of Government from the bill and the amount so recovered will be deposited in the State Bank of India at the credit of the firm.
18. The earnest money/Security deposit will be regulated as per the norms of C.P.W.D.
19. The Institute reserves the right of accepting or rejecting any quotations without assigning any reason thereof.
20. The material should be used as per approved list of make.

QUOTATION

Sub: Replacement of defective electric motor and starter at Lecture Hall 2 AHU room.

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
1	Supply, fixing, testing & commissioning of following capacity high efficiency motor suitable for fixing in existing tooling tower/AHU/Pump with necessary fitting, vibration isolator complete as reqd. (Make As per approved make)				
a)	7.5 HP, 415 Volts, 50 Hz, 04 pole, 1440 RPM	1.00	Nos.		
2	Supply, fixing, testing & commissioning of 7.5 HP 415 Volts New DOL starter type MU G6 with of following Amp. relay range complete as reqd. (Make Siemens or its equivalent)	1.00	Nos.		
3	Supply & fixing of dual duty taper locked bush and pulley of following size in existing unit of approved make complete in all respect including dismantling the old pulley and depositing the same sectional store.				
a)	150 mm 2B, 30mm	1.00	Nos.		
Total Rs.					


अधिकारी अनिरुद्धा (वाच) E.E. (A.C.)
सहनिर्देशक, वास्तु संस्थान, कानपुर
(W.D., LLT Kanpur)