



INDIAN INSTITUTE OF TECHNOLOGY KANPUR
DEPARTMENT OF MECHANICAL ENGINEERING
KANPUR-208016, INDIA

Dr. Avinash Kumar Agarwal,
Associate Professor

Tel: + 91 512 2597982 (O), + 91 512 2598682 (R)

Fax: + 91 512 259 7408

Email: akag@iitk.ac.in

<http://home.iitk.ac.in/~akag>

Enquiry no.: ME/ERL/2011-12/Nov/02

Enquiry date: November 4th, 2011

Last Date: November 14th, 2011

**Enquiry for Chiller Unit for temperature control of the AVL Fuel
Conditioning Unit**

Quotations are invited for purchase of **Chiller Unit for temperature control of the AVL Fuel Conditioning Unit** having following specifications.

Technical Data

Temperature control range:	adjustable from approximately 10° C to 80°C
Refrigerant gas:	R134A
Cooling power:	3.5 kW
Interfaces:	digital I/O
Ambient temperature:	5 -50° C
Power supply:	220V, 50 Hz

Scope of Supply Should Include:

- 1 Chiller Unit
- 1 Interface cable 5m
- 1 Power supply cables 10 m
- 1 Operating manual sets
- 1 Set Flexible water hoses and fittings

Installation and Services on-site

Project Management

The supplied equipment should be compatible with the AVL fuel Conditioning Unit.

Terms & Conditions:

- (i) Prices should include delivery upto Kanpur.
- (ii) Warranty should at least be for three years after installation.
- (iii) Validity of quotation should be at least for 90 days
- (iv) Delivery period: 1 Month from the date of PO

Kindly send your best offer (Technical & Commercial) so as to reach us on or before November 14th, 2011 to the following address:

Prof. Avinash Kumar Agarwal
Department of Mechanical Engineering
IIT Kanpur
Kanpur – 208016, India